

2410-41
2410-42
2410-43
FRONT END PROCESSOR
MAINTENANCE &
SUPPORT GUIDE

The information in this document has been carefully checked and is believed to be entirely reliable. However, no responsibility is assumed for inaccuracies. Furthermore, Cyclone Microsystems, Inc. reserves the right to make changes to any products herein to improve reliability, function, or design. Cyclone Microsystems, Inc. neither assumes any liability arising out of the application or use of any product or circuit described herein, nor does it convey any license under its right or the rights of others.

Revision 1.0, May 2006

DO NOT RELEASED FOR DISTRIBUTION

Cyclone P/N 800-2410-

Copyright 2006 by Cyclone Microsystems, Inc.

Revision Changes

Revision 1.0, May 2006

Chapter 1.2 Specifications

- (DC Only) Power Rating Changed from 36 -72 Vdc to -48 Vdc Nominal
- Regulatory Compliance: UL 60950-1:2003, First Edition and CSA C22.2 No. 60950-1-03 1st Ed. April 1, 2003

Chapter 3.1 Installation Guidelines

- Included Rack Mount Safety Warnings

CHAPTER 1

1.1 INTRODUCTION1-1
 1.2 SPECIFICATIONS.....1-1

CHAPTER 2

2.1 PHYSICAL CONFIGURATION (600-2410-43-D0)2-1
 2.2 PHYSICAL CONFIGURATION (600-2410-42-D0)2-2
 2.3 PHYSICAL CONFIGURATION (600-2410-41-D0)2-3
 2.4 PHYSICAL CONFIGURATION (600-2410-43-A0)2-4
 2.5 PHYSICAL CONFIGURATION (600-2410-42-A0)2-5
 2.6 PHYSICAL CONFIGURATION (600-2410-41-A0)2-6
 2.7 FEP FRONT PANEL2-7
 2.8 SWITCHES.....2-8
 2.8.1 FEP Power Supply Switches2-8
 2.8.2 FEP Reset Switch.....2-9
 2.9 CONNECTORS2-9
 2.9.1 Power Connector2-9
 2.9.1.1 DC Power Connectors2-9
 2.9.1.2 AC Power Connectors2-10
 2.9.1.3 Ground Studs2-11
 2.9.2 CPCI-824 Console Connector2-11
 2.9.3 10/100Base-T Ethernet Port Connector2-11
 2.9.4 10/100/1000Base-T Ethernet Port Connector2-12

CHAPTER 3

3.1 INSTALAATION GUIDELINES3-1

CHAPTER 4

4.1 FEP INITIALIZATION AND BUILT-IN SELF TEST4-1

CHAPTER 5

5.1 PERIODIC MAINTENANCE5-1

CHAPTER 6

6.1 SERVICEABLE COMPONENTS6-1
 6.2 BOARD REMOVAL AND INSTALLATION6-2
 6.2.1 Board Removal.....6-2
 6.2.2 Board Installation.....6-2
 6.3 FAN TRAY REMOVAL AND INSTALLATION6-2
 6.3.1 Fan / Filter Assembly Removal.....6-3
 6.3.2 Fan/Filter Assembly Installation.....6-3
 6.4 POWER SUPPLY REMOVAL AND INSTALLATION6-3
 6.4.1 Power Supply Removal6-3
 6.4.2 Power Supply Installation6-3

CONTENTS



CHAPTER 7

7.1	METHODOLOGY	7-1
7.2	ASSUMPTIONS	7-1
7.3	CONFIGURATION	7-2
7.4	RESULTS	7-2

CHAPTER 8

8.1	OVERVIEW	8-1
8.2	HARDWARE	8-1
8.3	SOFTWARE AND FIRMWARE	8-1
8.4	EFFECTIVE PERIOD OF WARRANTY	8-1
8.5	REPAIRED OR REPLACEMENT PRODUCT (OUT-OF-WARRANTY)	8-1
8.6	SERVICE POLICY	8-2

APPENDIX A

A.1	ADDITIONAL INFORMATION	A-1
-----	------------------------------	-----

LIST OF FIGURES

Figure 1-1. FEP Part Numbering1-1

Figure 2-1. 600-2410-43-D0 FEP Front Panel.....2-1

Figure 2-2. 600-2410-42-D0 FEP Front Panel.....2-2

Figure 2-3. 600-2410-41-D0 FEP Front Panel.....2-3

Figure 2-4. 600-2410-43-A0 FEP Front Panel.....2-4

Figure 2-5. 600-2410-42-A0 FEP Front Panel.....2-5

Figure 2-6. 600-2410-41-A0 FEP Front Panel.....2-6

Figure 2-7. FEP FRONT PANEL2-7

Figure 2-8. DC Power Connector.....2-10

Figure 2-9. AC Power Connector.....2-10

Figure 5-1 Air Filter Replacement5-2

LIST OF TABLES

Table 1-1. Specifications1-2

Table 2-1. 600-2410-43-D0 FEP Front Panel Description.....2-1

Table 2-2. 600-2410-42-D0 FEP Front Panel Description.....2-2

Table 2-3. 600-2410-41-D0 FEP Front Panel Description.....2-3

Table 2-4. 600-2410-43-A0 FEP Front Panel Description2-4

Table 2-5. 600-2410-42-A0 FEP Front Panel Description2-5

Table 2-6. 600-2410-41-A0 FEP Front Panel Description2-6

Table 2-7. FEP Front Panel LED Description2-7

Table 2-8. Ring Lugs for #10 Studs2-11

Table 2-9. Console Port Connector2-11

Table 2-10. 10/100 Ethernet Port Connector2-12

Table 2-11. 10/100/1000 Ethernet Port Connector.....2-12

Table 4-1. CPCI-824 Initialization LED Pattern Description4-1

Table 5-1. Air Filter Replacement5-1

Table 6-1. CLEI Number and Barcode6-1

1.1 INTRODUCTION

The 2410-43, 2410-42 and 2410-41 Front End Processor is a system featuring six Gigabit Ethernet ports and six Megabit Ethernet ports. The Gigabit ports can operate at 10/100/1000Base-T and the Megabit ports can operate at 10/100Base-T. The system uses three PowerPC processors spread out between three identical hot swappable cards. The 2410-43, 2410-42 and 2410-41 is available in AC or DC versions and features two redundant, hot swappable power supplies. The 2410-43, 2410-42 and 2410-41 system also monitors power supply, fan status and temperature in an effort to detect and provide early alert to component failures.

The part numbering system for the 600-2410 series of FEPs is as shown in Figure 1-1.




Figure 1-1. FEP Part Numbering

1.2 SPECIFICATIONS

Table 1-1 lists the specifications for the 2410-43, 2410-42 and 2410-41 series Front End Processor. Cooling air input is on the left side of the unit and the air exhaust is on the right side. Airflow should not be restricted; a minimum of one inch clearance on each side is required.

Table 1-1. Specifications

Physical	Height	5.25 inches
	Width	17.5 inches
	Depth	12 inches
	Other	19 inch rack mountable
	Weight	15 lbs
Electrical - AC version	Voltage:	90 - 264 Vac
	Current (Max):	3A
	Power Dissipation:	175 BTU/hr.
	Frequency:	47 - 63 Hz
	Connector:	
	Ethernet ports: Console serial ports: E1 ports:	10/100 BaseTx RJ45 RJ11 75ohm BNC, Transmit/Receive
Electrical - DC version	Voltage:	-48 Vdc Nominal
	Current (Max):	6.5A
	Power Dissipation:	175 BTU/hr.
	Connector:	
	Gigabit Ethernet ports: 100 Megabit Ethernet ports: Console Serial ports	10/100/100 BaseTx RJ45 10/100 BaseTx RJ45< RJ11 75 ohm BNC, Transmit/Receive

Environmental	Operating Temperature	0 to 55 Degrees Celsius
	Relative Humidity	0% to 95% (non-condensing)
	Storage Temperature	-55 to 125 Degrees Celsius
Regulatory Compliance	UL60950-1	
	<p>CUL C22.2 No. 950, CE Marking, FCC Class A</p> <p><u>Note:</u> This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.</p> <p><u>Caution:</u> Changes or modifications to this equipment not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.</p> <p>This digital apparatus does not exceed the Class A limits for radio noise emissions from digital apparatus set out in the Radio Interference Regulations of the Canadian Department of Communication.</p> <p>The equipment or subassembly is suitable for connection to intrabuilding or no exposed wiring or cabling only.</p> <p>Le present appareil numerique n'emet pas de bruits radioelectriques dépassant les limites applicables aux appareils numeriques de las classe A prescrites dans le Reglement sur le brouillage radioelectrique edicte par le ministere des Communications du Canada.</p>	

2.1 PHYSICAL CONFIGURATION (600-2410-43-D0)




Figure 2-1. 600-2410-43-D0 FEP Front Panel

Figure 2-1 shows a front view of the FEP unit with DC power supplies. Table 2-1 identifies each item.

Table 2-1. 600-2410-43-D0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		Power Connector B
3		FEP Power supply ON/OFF Switch
4		CPCI-824 Reset Switch
5		FEP Ground Lugs
6		Power Supply A
7		Power Supply B
8	0	CPCI-824
9	1	CPCI-824
10	2	CPCI-824
11		Fan/Filter Assembly

2.2 PHYSICAL CONFIGURATION (600-2410-42-D0)




Figure 2-2. 600-2410-42-D0 FEP Front Panel

Figure 2-2 shows a front view of the FEP unit with DC power supplies. Table 2-2 identifies each item.

Table 2-2. 600-2410-42-D0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		Power Connector B
3		FEP Power supply ON/OFF Switch
4		CPCI-824 Reset Switch
5		FEP Ground Lugs
6		Power Supply A
7		Power Supply B
8	0	CPCI-824
9	1	CPCI-824
10		Fan/Filter Assembly

2.3 PHYSICAL CONFIGURATION (600-2410-41-D0)




Figure 2-3. 600-2410-41-D0 FEP Front Panel

Figure 2-3 shows a front view of the FEP unit with DC power supplies. Table 2-3 identifies each item.

Table 2-3. 600-2410-41-D0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		Power Connector B
3		FEP Power supply ON/OFF Switch
4		CPCI-824 Reset Switch
5		FEP Ground Lugs
6		Power Supply A
7		Power Supply B
8	0	CPCI-824
9		Fan/Filter Assembly

2.4 PHYSICAL CONFIGURATION (600-2410-43-A0)




Figure 2-4. 600-2410-43-A0 FEP Front Panel

Figure 2-4 shows a front view of the FEP unit with AC power supplies. Table 2-4 identifies each item.

Table 2-4. 600-2410-43-A0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		FEP Power supply ON/OFF Switch A
3		Power Connector B
4		FEP Power supply ON/OFF Switch B
5		CPCI-824 Reset Switch
6		FEP Ground Lugs
7	0	CPCI-824
8	1	CPCI-824
9	2	CPCI-824
10		Power Supply A
11		Power Supply B
12		Fan/Filter Assembly

2.5 PHYSICAL CONFIGURATION (600-2410-42-A0)




Figure 2-5. 600-2410-42-A0 FEP Front Panel

Figure 2-5 shows a front view of the FEP unit with AC power supplies. Table 2-5 identifies each item.

Table 2-5. 600-2410-42-A0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		FEP Power supply ON/OFF Switch A
3		Power Connector B
4		FEP Power supply ON/OFF Switch B
5		CPCI-824 Reset Switch
6		FEP Ground Lugs
7	0	CPCI-824
8	1	CPCI-824
9		Power Supply A
10		Power Supply B
11		Fan/Filter Assembly

2.6 PHYSICAL CONFIGURATION (600-2410-41-A0)




Figure 2-6. 600-2410-41-A0 FEP Front Panel

Figure 2-6 shows a front view of the FEP unit with AC power supplies. Table 2-6 identifies each item.

Table 2-6. 600-2410-41-A0 FEP Front Panel Description

No.	SLOT#	Name
1		Power Connector A
2		FEP Power supply ON/OFF Switch A
3		Power Connector B
4		FEP Power supply ON/OFF Switch B
5		CPCI-824 Reset Switch
6		FEP Ground Lugs
7	0	CPCI-824
8		Power Supply A
9		Power Supply B
10		Fan/Filter Assembly

2.7 FEP FRONT PANEL




Figure 2-7. FEP Front Panel LEDs

Figure 2-7 shows a front view of the FEP unit. Table 2-7 briefly describes each item.

Table 2-7. FEP Front Panel LED Description

No.	SLOT#	Name	Description
1	0	CPCI-824 PWR0	Turns on and remains on for power good condition of power supply A and turns off for power failure.
2	0	CPCI-824 PWR1	Turns on and remains on for power good condition of power supply B.
3	0	CPCI-824 FN0	Turns on and remains on for FAN0 good condition and turns off for FAN0 failure.
4	0	CPCI-824 FN1	Turns on and remains on for FAN1 good condition and turns off for FAN1 failure.
5	0	CPCI-824 ST0	Indicates status 0 for CPCI-824 and will light And remain on for some time after a reset or power-on and turn off.
6	0	CPCI-824 ST1	Indicates status 1 for CPCI-824 and will light and remain on for some time after a reset or power-on and turn off.
7	0	CPCI-824 IOP	Indicates IOP for CPCI-824 and will light for a short time after a reset or power on and then turn off.
8	0	CPCI-824 ACT	Indicates CPCI-824 activity and will blink and/or vary in intensity as CPCI-824 performs different operations.

9	0	CPCI-824 Gbit Ethernet 0 ACT	Indicates network activity for port 0 and will blink during transmit and receive activity.
10	0	CPCI-824 Gbit Ethernet 0 LNK	Indicates link integrity for Ethernet port 0 and will remain on continuously if port 0 is connected to a functional network or Ethernet port.
11	0	CPCI-824 Gbit Ethernet 1 ACT	Indicates network activity for port 1 and will blink during transmit and receive activity.
12	0	CPCI-824 Gbit Ethernet 1 LNK	Indicates link integrity for Ethernet port 1 and will remain on continuously if port 1 is connected to a functional network or Ethernet port.
13	0	CPCI-824 10/100 Ethernet 0 ACT	Indicates network activity for port 0 and will blink during transmit and receive activity.
14	0	CPCI-824 10/100 Ethernet 0 LNK	Indicates link integrity for Ethernet port 0 and will remain on continuously if port 0 is connected to a functional network or Ethernet port.
15	0	CPCI-824 10/100 Ethernet 1 ACT	Indicates network activity for port 1 and will blink during transmit and receive activity.
16	0	CPCI-824 10/100 Ethernet 1 LNK	Indicates link integrity for Ethernet port 1 and will remain on continuously if port 1 is connected to a functional network or Ethernet port.
17	0	CPCI-824 Hot Swap	This will illuminate when it is permissible to extract the CPCI-824. It also lights at power-up and during reset and when the lower handle is open.
18	0	Power Supply A	The FEP Power Supply green 'POWER' LED is located on the power supply. It illuminates when the power supply is ON. The red 'FAULT' LED will light while the power supply is hot swapped, or if the power supply is faulty, or if there is no power supplied to the power entry module.
19	0	Power Supply B	The FEP Power Supply green 'POWER' LED is located on the power supply. It illuminates when the power supply is ON. The red 'FAULT' LED will light while the power supply is hotswapped or if the power supply is faulty, or if there is no power supplied to the power entry module.

2.8 SWITCHES

2.8.1 FEP Power Supply Switches

The 600-2410-43-D0, 600-2410-42-D0 and 600-2410-41-D0 DC unit has a single power switch. This switch enables and disables power from both power entries to both power supplies. The '1' position indicates power supply ON and '0' position indicates power supply OFF.

The 600-2410-43-A0, 600-2410-42-A0 and 600-2410-41-A0 AC unit has two power switches, each switch associated with one of the power entry modules. AC power switch A enables and disables power entry to power supply A and AC power switch B enables and disables power entry to power supply B.

2.8.2 FEP Reset Switch

The FEP Reset Switch does not have a function in this configuration. The CPCI-824s are stand-alone boards and each board has it's own reset switch mounted on the front panel.

2.9 CONNECTORS

2.9.1 Power Connector

There are two power supply connectors on the right hand side of the FEP.

2.9.1.1 DC Power Connectors

The DC power connector is military style circular bayonet connector with the contact arrangement and pin assignment as shown in Figure 2-4. Mating connector part numbers, backshell part numbers and cable clamp backshell part numbers are as follows:

Manufacturer	Mating Connector	Backshell	Cable Clamp Backshell
ITT Cannon	MS 3476 W14 4S MS 3475 W14 4S	057-0718-002	057-0685-002
Deutsch	MS 3476 W14 4S	94002-14-3014	94002-14-3014




Figure 2-8. DC Power Connector

The DC power wiring harness to 600-2410-43-D0, 600-2410-42-D0 and 600-2410-41-D0 should use 14 AWG wire and the color code as follows:

Color	Signal	Contact
Red	-48 VDC	A
Black	-48 VDC Return	B
Green/Yellow	Chassis ground	D

2.9.1.2 AC Power Connectors

The AC power connector is a 3-pin connector. See Figure 2-9.

The power Connector is a standard IEC type recessed power receptacle.




Figure 2-9. AC Power Connector

2.9.1.3 Ground Studs

There are two #10-32 threaded studs (with hex nuts, flat washers and star washers included) attached to the chassis of the FEP. Ring lugs should be used to attach chassis ground to the ground studs. Table 2-8 shows AMP/Tyco part numbers for typical ring lugs for #10 studs.

Table 2-8. Ring Lugs for #10 Studs

Wire Gauge	AMP/Tyco Part
14-16 AWG	320630
10-12 AWG	36161

2.9.2 CPCI-824 Console Connector

The CPCI-824 Console Connector is a narrow RJ11 (6 positions) phone jack. The console port is an RS232 serial port using a simple three-wire connection (transmit data, receive data & ground). The connector assignment is as shown in Table 2-9. Normal system operation does not require a connection to the CPCI-824 console connector.

Diagnostic or debug activity may require connecting to the CPCI-824 console connector. A cable connecting the console port to a standard DB25 connector is available from Cyclone Microsystems (P/N 530-2006). A terminal (or PC running a terminal emulation program) should be set up for any baud up to 115K baud, 8 bits, no parity and 1 stop bit.

Table 2-9. Console Port Connector

Pin	Signal	Description
1	-	N/C
2	GND	Ground
3	TXD	Transmit Data
4	RXD	Receive Data
5	-	N/C
6	-	N/C

2.9.3 10/100Base-T Ethernet Port Connector

The Ethernet Ports Connector 10/100 Base TX is a shielded RJ45 phone jack. The pin assignments are as shown in Table 2-10.

Table 2-10. 10/100 Ethernet Port Connector

Pin	Signal	Description
1	TX+	Transmit + (output)
2	TX-	Transmit - (output)
3	RX+	Receive + (input)
4	-	N/C
5	-	N/C
6	RX-	Receive – (input)
7	-	N/C
8	-	N/C

2.9.4 10/100/1000Base-T Ethernet Port Connector

The Ethernet Ports Connector 10/100/1000 Base TX is a shielded RJ45 phone jack. The pin assignments are as shown in Table 2-11.


Table 2-11. 10/100/1000 Ethernet Port Connector

Pin	Signal (10/100Base-T)	Description (10/100Base-t)	Signal (1000Base-T)	Description (1000Base-T)
1	-	Not Used	-	N/C
2	-	Not Used	TRD2-	Input/Output
3	-	Not Used	TRD2+	Input/Output
4	RX+	Input	TRD1+	Input/Output
5	RX-	Input	TRD1-	Input/Output
6	-	Not Used	-	N/C
7	-	Not Used	-	N/C
8	-	Not Used	TRD3+	Input/Output
9	-	Not Used	TRD3-	Input/Output
10	TX-	Output	TRD0-	Input/Output
11	TC+	Output	TRD0+	Input/Output
12	-	Not Used	-	N/C
13	-	Not Used	-	N/C
14	-	Not Used	-	N/C
15	-	Not Used	-	N/C
16	-	Not Used	-	N/C

3.1 INSTALLATION GUIDELINES

The following guidelines and instructions apply to the 2410-43, 2410-42 and 2400-41.

- 1.This unit is for use only in a Restricited Access Location (RAL).
- 2.The external grounding terminals are marked with symbol



(60417-1-IEC-5019).

- 3.These 2 grounding terminals must be connected to earth ground.
- 4.Do not connect or disconnect the power connector under load
- 5.The DC power supply cord must be protected against physical damage.
- 6.Elevated Operating Ambient - If installed in a closed or multi-unit rack assembly, the operating ambient temperature of the rack environment may be greater than room ambient. Therefore, consideration should be given to installing the equipment in an environment compatible with the maximum ambient temperature (T_{ma}) specified by the manufacturer.
- 7.Reduced Air Flow - Installation of the equipment in a rack should be such that the amount of air flow required for safe operation of the equipment is not compromised.
- 8.Mechanical Loading - Mounting of the equipment in the rack should be such that a hazardous condition is not achieved due to uneven mechanical loading.
- 9.Circuit Overloading - Consideration should be given to the connection of the equipment to the supply circuit and the effect that overloading of the circuits might have on overcurrent protection and supply wiring. Appropriate consideration of equipment nameplate ratings should be used when addressing this concern.
- 10.Reliable Earthing - Reliable earthing of rack-mounted equipment should be maintained. Particular attention should be given to supply connections other than direct connections to the branch circuit (e.g. use of power strips).

CHAPTER 4

FEP INITIALIZATION AND BUILT-IN SELF TEST

4.1 FEP INITIALIZATION AND BUILT-IN SELF TEST

The CPCI-824 board displays on the IOP, ACT, STO and ST1 LEDs the status of the boards initialization and diagnostic self test.

FEP initialization firmware illuminates various user LED patterns after completing early stages of hardware initialization. Should the board fail to boot properly, the LED pattern will indicate the last successfully completed stage of the board initialization sequence. The following table describes the startup LEDs.

Table 4-1. CPCI-824 Initialization LED Pattern Description

All LEDs On	Reset Applied
All LEDs Off	Executing Reset vector.
Port 0 Act On Port 0 Lnk On	GT-64130 in single GT mode.
Port 0 Act On Port 0 Lnk On Port 1 Lnk On	SDRAM memory controller initialized.
Port 0 Act On Port 0 Lnk On Port 1 Lnk On Port 1 Act On	MPC8260 internal registers initialized.
Port 0 Act On Port 0 Lnk On Port 1 Lnk On Port 1 Act On Port 2 Lnk On	MMU initialized. Code copied to SDRAM
Port 0 Act On Port 0 Lnk On Port 1 Lnk On Port 1 Act On Port 2 Lnk On Port 2 Act On	Program executing from SDRAM.

FEP INITIALIZATION AND BUILT-IN SELF TEST



All LEDs On	Reset Applied
All LEDs Off	System Level initialization continuing.
Port 3 Act On	MPC8260 CPM reset and initialized. Serial port initialized. Instruction cache enabled. Data cache enabled. Exception vectors initialized. CPCI bridge initialized.
Port 3 ACT On, Port 3 Lnk On	InitBoard Completed. Entering pSOSystem. LEDs are under application control at this point. TFTP Boot application firmware does not utilize the LEDs.

5.1 PERIODIC MAINTENANCE

The only element of the FEP unit requiring periodic maintenance is the air filter, located on the left hand side of the unit. The filter should be replaced or cleaned every 12 months in normal operating environments. It should be replaced more often in dusty environments.

The replacement of air filter or fan should be done with power off. The fan and air filter assembly is located on the left hand side of the FEP unit. Replacement filters can be purchased from Cyclone Microsystems, Cyclone part number 370-1303.

Table 5-1. Air Filter Replacement

1	Loosen the four screws retaining the Fan & Air Filter assembly.
2	Remove the Fan & Air Filter assembly.
3	The air flow element slides out the narrow opening in the Fan & Air Filter assembly. (see Figure 4-1)
4	Slide a new filter element into the narrow opening in the Fan & Air Filter assembly.
5	Install the Fan & Air Filter assembly.
6	Snug the four retaining screws using a Phillips screwdriver.




Figure 5-1. Air Filter Replacement

6.1 SERVICEABLE COMPONENTS

All of the Field Replaceable Units (FRU) of an FEP are serviceable from the front of the unit without the need to dismount an installed FEP from its rack. Table 5-1 lists all the field replaceable units and the associated CLEI codes and Cyclone part numbers.

Table 6-1. CLEI Number and Barcode

Cyclone Part Number	Qty	Description	CLEI Number	ECI Code Barcode
600-2410-43-A0				
600-2014	1	5 slot CPCI-AC: 2410 Chassis	ANM1P00ERA	449528
CM824-1G-T3	3	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1302-02	2	AC Power supply: 2410 Chassis	ANPUK30MAA	142035
370-1300	1	Fan / Filter Assembly: 2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2400/2410 Chassis		
600-2410-43-D0				
600-2015	1	5 slot CPCI-DC: 2410 Chassis	ANM1R00ERA	449529
CM824-1G-T3	3	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1301-02	2	DC Power supply: 2400 /2410Chassis	ANPUL40MAA	142037
370-1300	1	Fan / Filter Assembly: 2400/2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2400/2410 Chassis		
600-2410-42-A0				
600-2014	1	5 slot CPCI-AC: 2410 Chassis	ANM1P00ERA	449528
CM824-1G-T3	2	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1302-02	2	AC Power supply: 2410 Chassis	ANPUK30MAA	142035
370-1300	1	Fan / Filter Assembly: 2400/2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2410 Chassis		
600-2410-42-D0				
600-2015	1	5 slot CPCI-DC: 2410 Chassis	ANM1R00ERA	449529
CM824-1G-T3	2	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1301-02	2	DC Power supply: 2410 Chassis	ANPUL40MAA	142037
370-1300	1	Fan / Filter Assembly: 2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2400/2410Chassis		

600-2410-41-A0				
600-2014	1	5 slot CPCI-AC: 2410 Chassis	ANM1P00ERA	449528
CM824-1G-T3	1	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1302-02	2	AC Power supply: 2410 Chassis	ANPUK30MAA	142035
370-1300	1	Fan / Filter Assembly: 2400/2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2400/2410 Chassis		
600-2410-41-D0				
600-2015	1	5 slot CPCI-DC: 2410 Chassis	ANM1R00ERA	449529
CM824-1G-T3	1	CPCI-824 Processor Board with Four Ethernet Ports	ANC4SW0GAA	142029
370-1301-02	2	DC Power supply: 2410 Chassis	ANPUL40MAA	142037
370-1300	1	Fan / Filter Assembly: 2400/2410 Chassis	GCNYAANFAA	436784
370-1303		Filter (only): 2400/2410Chassis		

6.2 BOARD REMOVAL AND INSTALLATION

The CPCI-824 is hot-swappable and can be removed or installed with power ON or OFF. All cables should be disconnected from the boards during installation and removal.

6.2.1 Board Removal

FEP Boards can be damaged with electrostatic discharge. Consequently, all boards should be handled in an environment with preventive Electro Static Discharge (ESD) measures. Specifically, boards should only be actively handled with a ground strap and transported in an ESD shielded bag.

Disconnect cables from the board. Loosen the two retaining screws on the boards front panel. The retaining screws are located on each edge of the front panel, between the ejector handles and the end of the front panel. Eject the board by prying outward on both the ejector handles.

6.2.2 Board Installation

Insert the board into the FEP unit opening and align the printed circuit board card edge with the card guides inside the unit. Care should be taken to insert the board horizontally (as flat as possible) so as not to interfere with components on the board below or interfere with the underside of the board above. Fully seat the board by pressing firmly on both ejector handles or pressing at the center of the board's front panel.

6.3 FAN TRAY REMOVAL AND INSTALLATION

The cooling fans of the FEP are serviceable from the front of the unit. The FEP does NOT have to be removed from its rack to service the fans.

6.3.1 Fan / Filter Assembly Removal

Follow steps 1 and 2 in Table 4-1 to remove the Fan/Filter assembly panel. The Fan/Filter assembly is located on the left side of the unit as shown in Figure 4-1. The Fan/Filter assembly has a finger pull. Pull the fan tray from the unit.

6.3.2 Fan/Filter Assembly Installation

Align the flanges in the Fan /Filter assembly with its guides after replacing the fan and slide the Fan/Filter access panel into the unit.

6.4 POWER SUPPLY REMOVAL AND INSTALLATION

The AC power supply has 2 switches for 2 power supplies and the DC power supply has a single switch for 2 power supplies. The power supplies of the FEP are serviceable from the front of the unit. The FEP does NOT have to be removed from its rack to service the power supplies. The FEP will operate with one power supply installed. Since the power supplies are hot swappable, they can be removed or installed without switching off the power.

6.4.1 Power Supply Removal

The two power supplies of the FEP are located above the boards, at the top of the unit. To remove failed power supply, loosen the two retaining screws, at either end of the power supply. Eject the power supply from the FEP by prying outward on the ejector handle. Pull the power supply from the unit.

6.4.2 Power Supply Installation

With the printed circuit board of the power supply aligned with the card guides of the FEP unit, slide the power supply into the FEP. Fully seat the power supply and tighten the retaining screws.

7.1 METHODOLOGY

Reliability predictions were completed using the Bellcore 5 reliability standard developed by AT&T Bell Laboratories. Component failure rates are calculated based on technology, stress levels, gate or transistor density (ICs), package style, and quality level. Failure rates provided by the component manufacturer have been used in some cases, where available. Failure rates are expressed in FITs, which is failures per billion hours. Mean Time Between Failures (MTBF) is the inverse of the failure rate and is the average time between failures.

7.2 ASSUMPTIONS

- Ambient input air temperature does not exceed 30 deg. C.
- Ground, Fixed, Controlled Environment
- Components are Quality Level I.
- Component stress levels do not exceed rated limits (i.e. power dissipation, junction temperature, etc.). In other words, components are used within specification limits. The parts count prediction assumes parts are used at a maximum of 50% of rated electrical stress.
- Component failure could result in FEP failure (except for the power supplies that are configured in parallel redundancy). However, Bellcore's architecture uses FEPs in parallel redundancy.

7.3 CONFIGURATION

Item	Part Number	Failure Rate 25°C	MTBF 25°C	Failure Rate 30°C	MTBF 30°C
	600-2410-43-D0				
CPCI-824	CM821-064-00-Te	3248	307882	4842	206526
DC Power Supply: 2410 Chassis	370-1301-02	2172	460405	2172	460405
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000
	600-2410-43-A0				
CPCI-824	CM824-1G-T3	3248	307882	4842	206526
AC Power Supply: 2410 Chassis	370-1302-02	2332	428816	2332	428816
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000
	600-2410-42-D0				
CPCI-824	CM821-064-00-T3	2920	342466	3228	309789
DC Power Supply: 2410 Chassis	370-1301-02	2172	460405	2172	460405
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000
	600-2410-42-A0				
CPCI-824	CM824-1G-T3	2920	342466	3228	309789
AC Power Supply: 2410 Chassis	370-1302-02	2332	428816	2332	428816
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000
	600-2410-41-D0				
CPCI-824	CM821-064-00-T3	1460	684932	1614	619579
DC Power Supply: 2410 Chassis	370-1301-02	2172	460405	2172	460405
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000
	600-2410-41-A0				
CPCI-824	CM824-1G-T3	1460	684932	1614	619579
AC Power Supply: 2410 Chassis	370-1302-02	2332	428816	2332	428816
Fan/Filter Assembly: 2400/2410 Chassis	370-1300	100	10000000	100	10000000

7.4 RESULTS

ITEM	Failure Rate 25 ⁰ C	MTBF 25 ⁰ C	Failure Rate 30 ⁰ C	MTBF 30 ⁰ C
600-2410-43-D0	5520	181,159	7114	140568
600-2410-43-A0	5680	176,056	7274	137476
600-2410-42-D0	5192	192,604	5500	181818
600-2410-42-A0	5352	186,846	5660	176678
600-2410-41-D0	3732	267,953	3886	257334
600-2410-41-A0	3892	256,937	4046	247158

CHAPTER 8 WARRANTY

8.1 OVERVIEW

Cyclone Microsystems is a commercial manufacturer of Single Board Computers, Intelligent Communication Controllers and communications systems. Our standard repair cycle for in-warranty or out-of-warranty repair is two weeks. Most of our FEP customers require 24 by 7 support that is far in excess of Cyclone Microsystems' current or anticipated capabilities. Consequently, we highly recommend that FEP customers pursue high availability support from a support organization or pursue an on-site sparing policy in conjunction with a Cyclone Microsystems Expedited Repair Program. Please contact a Cyclone sales representative for a program proposal.

8.2 HARDWARE

Cyclone Microsystems, Inc. (Cyclone) for the period set out below, warrants that its standard products will be free from defects in workmanship or material under normal use and service. Cyclone's obligation under this warranty shall not arise until the Buyer returns the defective product, freight prepaid, to Cyclone. The only responsibilities of Cyclone under this warranty are at its option to replace or repair, without charge, any defective component of such products.

8.3 SOFTWARE AND FIRMWARE

Cyclone warrants that Software and Firmware supplied shall conform to the then current published documentation applicable to such programs. Cyclone, for the effective period of the warranty set out below, will upon written notice from the Buyer documenting the symptoms or the defect, expend its best efforts to resolve software bugs and/or fault. This service shall be without extra charge, and at Cyclone's option may include on-site visit(s) if in its opinion the conditions justify such visit(s).

8.4 EFFECTIVE PERIOD OF WARRANTY

One year from date of delivery.

8.5 REPAIRED OR REPLACEMENT PRODUCT (OUT-OF-WARRANTY)

Cyclone Microsystems, for a period of 30 days, warrants that its out-of-warranty products that are repaired or replaced shall be free from defects in workmanship or material under normal use and service.

Any repair or replacement shall not extend the period within which the warranty can be asserted.

The above warranties do not extend to and shall not apply to:

- Products which have been repaired or altered by other than Cyclone, unless the Buyer has properly altered or repaired the products in accordance with procedures previously approved, in writing, by Cyclone; or

WARRANTY



- Products which have been subject to misuse, neglect, accident or improper installation; or
- Products not manufactured by Cyclone.

The foregoing warranty and remedies are exclusive and are made in lieu of all other warranties express or implied, either in fact or by operation of law, statutory or otherwise, including warranties of merchantability and fitness for use. Cyclone neither assumes nor authorizes any other person to assume for it any other liability in connection with the sale, installation or use of its products, and Cyclone makes no warranty whatsoever for products not manufactured by Cyclone or with respect to any non-standard products which have been subject to misuse, neglect, accident, or have been modified by the Buyer. Cyclone shall have no liability for incidental or consequential damages of any kind arising out of the sale, installation, or use of its products.

8.6 SERVICE POLICY

Out of repair warranty will be accomplished expeditiously at a charge published on the current price schedule plus shipping. A full description of the failure must be enclosed with the product.

Shipments arriving at Cyclone without a Return Material Authorization (RMA) number will not be accepted and will be returned to the customer at his cost regardless of warranty status.

Return Procedures

Upon determining that repair is required, the customer must:

- Call Cyclone Customer Support at (203) 786-5536 for a RMA number. Please have ready:
 - The serial number of the board (s)
 - The reason for return
- Enclose a detailed description of the failure with the failed unit in a static-shielded protective container.
- Ship unit to: Cyclone Microsystems, 370 James Street, New Haven, CT 06513, Attn: RMA number
- The RMA is valid for 30 days after issue.



APPENDIX A MANUALS

A.1 ADDITIONAL INFORMATION

Additional information for each of the boards used in the FEP can be found in their respective User's Manual. These manuals are available from Cyclone Microsystems.

Part Number	Description
800-0824	CPCI-824 User's Manual